



- NOTES:**
- HIGH WATER ALARM (HWA) AND LOW WATER ALARM (LWA) SHALL BE ANNUNCIATED AT THE FIRE PUMP CONTROL PANEL OR LOCATION DETERMINED BY THE OWNER.
 - FLOAT SWITCHES (NON-MERCURY TYPE) SHALL BE USED TO MONITOR HWA AND LWA.
 - PROVIDE TEMPERATURE SENSOR TO MEASURE CRITICAL WATER TEMPERATURE AS REQUIRED BY NFPA 20. TEMPERATURE SHALL BE MONITORED AT THE FIRE PUMP CONTROL PANEL OR LOCATION DETERMINE BY THE OWNER.
 - PROVIDE TWO HILLSIDE NOZZLES FOR INSTALLATION OF FLOAT SWITCHES.

NOTE:
THE DETAILS SHOWN ON THE DRAWINGS INDICATE GENERAL INTENT ONLY. ALL SUCH ELEMENTS SHALL BE DESIGNED TO COMPLY WITH NFPA 13-2007 AND 22-2003.

TIMMONS GROUP
A PROFESSIONAL LIMITED COMPANY
1001 Boulders Parkway, Suite 300
Richmond, VA 23225
TEL 804.200-6500
FAX 804.560-1016

mbj ARCHITECTURE
A Professional Limited Company
GROVE PARK SQUARE
11537-B NUCKOLS ROAD
Glen Allen, Virginia 23059
(804) 273-9811 fax: (804) 273-9843

**RAPPAHANNOCK
COMMUNITY COLLEGE
CAMPUS RENOVATIONS
WARSAW + GLENN, VIRGINIA**
PC: 260-17712

**TANK AND
WATERLINE DETAILS**

Date: JANUARY 13, 2010
REVISIONS
NO. DATE
REV. WORK 3/3/2010

COMMONWEALTH OF VIRGINIA
WESLEY G. HUNNIUS
Lic. No. 0401512
PROFESSIONAL ENGINEER

Sheet
U1.2
File Number
28389